

## Chuck Fisher

---

**From:** Travis See <tsee@myrec.coop>  
**Sent:** Friday, August 21, 2020 11:19 AM  
**To:** chuck@farrow.com  
**Subject:** Kentmere drive and McGhee Rd  
**Attachments:** Kentmere and McGhee.pdf

Chuck,

I have attached a portion of our maps to this email.

We currently have overhead 3-phase, 12.5Kv along Kentmere , we also have single phase underground serving the water tank. Lastly we have 3-phase 12.5Kv overhead power along McGhee Rd. It appears that each of the listed properties you provided me, does have access to power.

Thanks  
Travis See  
Rappahannock Electric Cooperative

-Rappahannock Electric Cooperative Legal Disclaimer-

This message may contain confidential and/or proprietary information, and is intended for the person/entity to whom it was originally addressed. Any use by others is strictly prohibited.

